

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:59 pm

PWS ID: UTAH26044 **Name:** PINE HOLLOW WATER COMPANY
Legal Contact: PINE HOLLOW WATER COMPANY **Rating:** Not Approved
 RICK WOODARD **Rating Date:** 02/15/2007
Address: 1585 S STATE ST **Activity Status:** Active
 OREM, UT 84097
Phone Number: 435-377-1903
City Served (Area):
County: WASATCH COUNTY
System Type: Non-community **Last Inv Update:** 08/09/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 07/18/2008 **Total Dsgn Cap:**
Population: 250 **Surveyor:** DWIGHT HILL **Total Emerg Cap:**
Oper Period: 5/1 to 9/30

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers	Email Address
			Office	Emergency
AC	WOODARD, RICK		801-377-1903	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unknown	0	65
			65 Total Svc Connections

Storage

Total Storage: 28,500 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	PINE HOLLOW #1	Ground	28,500 GAL	Steel		A	NO

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	PINE HOLLOW BOOSTER STATION	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1	Active	WL	8	8 GPM		Yes	GW	Seasonal	5/1 to 9/30	
WS002	WELL #2	Active	WL	8	15 GPM		Yes	GW	Seasonal	5/1 to 9/30	

*Reports measured flow for wells, approved design capacity for all other sources.